






**SAFETY INSTRUCTIONS**

1-9, 11-23, 25-27, 28a/b - 31,34

**PAULMANN LICHT GmbH**  
Quezinger Feld 2 • D-31832 Springe  
[www.paulmann.com](http://www.paulmann.com)  
☎ +49 (0) 5041 998 389

7<sup>00</sup>-20<sup>00</sup>  
Mon. - Fri.



**Transfo Mipro S 80VA**

<input checked="" type="checkbox"/> R.L.C.	<b>SAFETY INSTRUCTIONS</b> Nr. 28a/b !!	Ta: 0...+45°C	
<input checked="" type="checkbox"/> R.C.	<b>SAFETY INSTRUCTIONS</b> Nr. 28a !!	TC: +85°C	

<p><b>230V PRI</b></p>	<p><b>12V SEC</b></p>
------------------------	-----------------------

<input checked="" type="checkbox"/> H03VVH2-F } min. 2x 0,75mm <sup>2</sup> <input type="checkbox"/> H03VV-F <input type="checkbox"/> H05VVH2-F <input type="checkbox"/> H05VV-F	<input checked="" type="checkbox"/> H03VVH2-F } min. 2x 0,75mm <sup>2</sup> <input type="checkbox"/> H03VV-F <input type="checkbox"/> H05VVH2-F <input type="checkbox"/> H05VV-F
---	---

**Transfo Mipro S 105VA**

<input checked="" type="checkbox"/> R.L.C.	<b>SAFETY INSTRUCTIONS</b> Nr. 28a/b !!	Ta: 0...+40°C	
<input checked="" type="checkbox"/> R.C.	<b>SAFETY INSTRUCTIONS</b> Nr. 28a !!	TC: +75°C	

<p><b>230V PRI</b></p>	<p><b>12V SEC</b></p>
------------------------	-----------------------

<input checked="" type="checkbox"/> H03VVH2-F } min. 2x 0,75mm <sup>2</sup> <input type="checkbox"/> H03VV-F <input type="checkbox"/> H05VVH2-F <input type="checkbox"/> H05VV-F	<input checked="" type="checkbox"/> H03VVH2-F } min. 2x 0,75mm <sup>2</sup> <input type="checkbox"/> H03VV-F <input type="checkbox"/> H05VVH2-F <input type="checkbox"/> H05VV-F
---	---